

Wal-Mart at Cutler

Administrative Amendment Request

Project #PR- 2021-005016

Transportation Development Comments:

Contact: Jeanne Wolfenbarger 924-3991, jwolfenbarger@cabq.gov

1. For centerline striping, the ratio of the gap to the stripe should be 3:1.
2. Provide "Yield to Pedestrian" signage on either side of the main crosswalk entrance per MUTCD requirements.
3. In the package, I did not see any details for signage and striping or a plan for parking spaces that involve pick-up only, similar to the other Wal-Mart packages. Please make sure to provide all plans.
4. Be sure to cross out keyed notes that are not used for this submittal. For any detail sheets provided, delete any signage that is not being used.