DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2021-005017 Hearing Date: **2-10-2021**

Project: 4110 Waterwillow Agenda Item No: **17**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Please provide a diagram which shows existing drainage flows. If flows cross over proposed lot line then a cross lot drainage easement will be required stating beneficiary and maintenance responsibilities.
- Note: An approved Grading and Drainage plan will be required if future development meets any of the following conditions: 500 cy of grading, 1000 sf of proposed building, 10,000 sf of proposed paving.

RESOLUTION/COMMENTS:

Parks & Rec.:

Code:

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____