DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2019-005076 AGENDA ITEM NO: 21

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. New DPM requirements show 5-foot sidewalk versus a 4-foot sidewalk requirement and a required minimum right-of-way width of 48 feet versus 47 feet for the cul-de-sac. Abide by new requirements or provide justification for proposing widths shown on the plat.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: Feb. 24, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)