Albuquerque Bernalillo County
Water Utility Authority

Development Review Board (DRB)
Review Comments
Utility Development Section
Reviewer: Blaine Carter, P.E.
Phone: 505.415.9188

DRB Project No:	Date:	Item No:
PR-2021-005195	3/30/22	#8
Zone Atlas Page: D-17	Legal Description: Tract 6A-1, Unit 1, Journal Center Phase 2 Location: 7501 JEFFERSON ST NE between JEFFERSON ST and MASTHEAD ST NE	
Request For: SI-2021-01747 – SITE PLAN		

ABCWUA Comment:

Please provide written description of how the following comments were addressed with the next submittal.

1. No new files received. Previous comments below.
2. No objections.
3. Availability Statement #211006 has been executed and provides criteria for service.
4. Routine connections via a mini-work order are the requirements for this project. These connections can be incorporated into a City DRC if that process is required by other departments.
5. This project is within the adopted service area.
6. Pro rata is not owed for this property.
7. Utility Plan:
    a. The sewer connection on the provided utility plan does not acknowledge the larger interceptor main that is beneath the collector main. The proposed manhole will need to accommodate both mains, i.e. not be built over the interceptor main.
8. Infrastructure List:
    a. The sanitary sewer manhole connection is the only anticipated ABCWUA improvement.