

**DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION**  
 Ernest Armijo, PE Principal Engineer | 505-924-3986 [earmijo@cabq.gov](mailto:earmijo@cabq.gov)

---

DRB Project Number: 2020-005238 Hearing Date: 3-31-21  
 Project: 4632 Cactus Ave Agenda Item No: 28

|   |   |   |  |
|---|---|---|--|
| <input checked="" type="checkbox"/> Sketch Plat | <input type="checkbox"/> Minor Preliminary / Final Plat | <input type="checkbox"/> Preliminary Plat   | <input type="checkbox"/> Final Plat                      |
| <input type="checkbox"/> Temp Sidewalk Deferral | <input type="checkbox"/> Sidewalk Waiver/Variance       | <input type="checkbox"/> Site Plan for Bldg. Permit<br><input type="checkbox"/> Site Plan for Subdivision | <input type="checkbox"/> Bulk Land Plat                  |
| <input type="checkbox"/> SIA Extension          | <input type="checkbox"/> DPM Variance                   | <input type="checkbox"/> Vacation of Private Easement   | <input type="checkbox"/> Vacation of Public Right of Way |

**ENGINEERING COMMENTS:**

- For Information. If future development exceeds 1000sf of building, 10000sf of paving, 500cy of grading or 1ac of grading, an approved grading and drainage plan will be required prior to building permit.

**RESOLUTION/COMMENTS:**

Code:

Water:

Transportation:

Planning:

Parks & Rec.:

APPROVED  
 DENIED

DELEGATED TO:  TRANS  HYD  WUA  PRKS  PLNG  
 Delegated For: \_\_\_\_\_  
 SIGNED:  I.L.  SPSP  SPBP  FINAL PLAT  
 DEFERRED TO \_\_\_\_\_