DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2021-005288 AGENDA ITEM NO: 12
High Desert Road

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. A minimum 5-foot wide sidewalk is required along the entire frontage of the property on both streets. Measure the existing walkway width along High Desert Road; deviation from this width would require a sidewalk width waiver request.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: April 7, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)