

**DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION**  
 Ernest Armijo, PE, Principal Engineer | 505-924-3986 [earmijo@cabq.gov](mailto:earmijo@cabq.gov)

---

DRB Project Number: 2021-005296 Hearing Date: 4-7-2021  
 Project: 720 Candelaria Agenda Item No: 10

<input type="checkbox"/> Sketch Plat	<input type="checkbox"/> Minor Preliminary / Final Plat	<input type="checkbox"/> Preliminary Plat	<input checked="" type="checkbox"/> Final Plat
<input type="checkbox"/> Temp Sidewalk Deferral	<input type="checkbox"/> Sidewalk Waiver/Variance	<input type="checkbox"/> Site Plan for Bldg. Permit <input type="checkbox"/> Site Plan for Subdivision	<input type="checkbox"/> Bulk Land Plat
<input type="checkbox"/> SIA Extension	<input type="checkbox"/> DPM Variance	<input type="checkbox"/> Vacation of Public Easement	<input type="checkbox"/> Vacation of Public Right of Way

**ENGINEERING COMMENTS:**

- Hydrology has no objection to the plat
- Please note: An approved Grading and Drainage plan will be required prior to building permit if any of these conditions are met: 500 cy of grading, 1000 sf of proposed building, or 10000 sf of proposed paving.

**RESOLUTION/COMMENTS:**

Code:

Water:

Transportation:

Planning:

Parks:

APPROVED  
 DENIED

DELEGATED TO:  TRANS  HYD  WUA  PRKS  PLNG  
 Delegated For: \_\_\_\_\_  
 SIGNED:  I.L.  SPSP  SPBP  FINAL PLAT  
 DEFERRED TO \_\_\_\_\_