DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2021-005628 Hearing Date: **4-27-2022**

Project: Mesa Del Sol Innovation Park City Center Agenda Item No: **5**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☒ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has an approved Conceptual Grading and Drainage plan (R16D097B) with engineer's stamp date of 10/21/21.
- No objection

RESOLUTION/COMMENTS:

Water:

Code:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____