DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2021-005716 Hearing Date: **06-08-2022**

Project: Tract 93A3, MRGCD Map 40 Agenda Item No: **19**

| | | | |
|---|---|---|---|
| ☒ Sketch Plat | ☐ Minor Preliminary / Final Plat | ☐ Preliminary Plat | ☐ Final Plat |
| ☐ Temp Sidewalk Deferral | ☐ Sidewalk Waiver/Variance | ☐ Site Plan for Bldg. Permit<br>☐ Site Plan for Subdivision | ☐ Bulk Land Plat |
| ☐ SIA Extension | ☐ DPM Variance | ☐ Vacation of Public Easement | ☐ Vacation of Public Right of Way |

**ENGINEERING COMMENTS:**

- Hydrology has no objection to the platting action.
- **Comment** – Per § 14-5-2 of the Albuquerque Code of Ordinances, Hydrology will need to approve a Grading and Drainage Plan prior to Building Permit if one of these conditions is met:
    - 500 CY of grading (earthwork)
    - 1,000 SF of proposed building
    - 10,000 SF of proposed paving

**RESOLUTION/COMMENTS:**

Water:

Code:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____