Albuquerque Bernalillo County
Water Utility Authority

Development Review Board (DRB)
Review Comments
Utility Development Section
Reviewer: Andre Houle, P.E.
Phone: 505.304.5993

DRB Project No:	Date:	Item No:
PR-2021-005904	9/21/22	#18
Zone Atlas Page: K-9, L-9	Legal Description: Lot(s) 19 THRU 27 BLOCK 10, ORIGINAL TOWNSITE OF WESTLAND Location: 9700-9722 CENTRAL AVENUE SW	
Request For: PS-2022-00211 – SKETCH PLAT		

ABCWUA Comment:

Please provide written description of how the following comments were addressed with the next submittal.

1. The subject parcel(s) have an existing ABCWUA water and sewer account.
2. Public water distribution mains and public sewer collection mains front the property and are available for direct tapping for a routine service connection.
3. This project is within the Adopted Service Area.
4. Plat:
    a. When existing infrastructure is located along the property frontage(s), but plans are uncertain and no Availability Statement is being required, the following language shall be included on the plat for approval:
        i. "Existing public water and/or sanitary sewer infrastructure may not be constructed or sized to adequately serve potential future development. Improvement or upsizing of existing public infrastructure may be required as a condition of future development approval."