DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2021-005904 Hearing Date: **1-26-2022**

Project: 9722 Central Ave. SW Agenda Item No: **1**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☒ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has no objection to the vacation.
- Note: Any future development will require an approved Grading and Drainage Plan if any of the following conditions are met; 500 cy of grading, 1,000 sf of proposed structure, 10,000 sf of proposed paving.

RESOLUTION/COMMENTS:

Water:

Code:

Parks & Rec.:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____