DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006070 AGENDA ITEM NO: 3
Daytona and Bluewater corner

SUBJECT: Plat

ENGINEERING COMMENTS:

1. On the infrastructure, list curb height for new road.
2. Provide temporary turn-around in the form of an easement off of Daytona Road at the accessway to the site until the road can be extended.
3. Right-of-way shall match the cross-section width shown for Bluewater (70 feet versus 68 feet).

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: January 5, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)