DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2021-006255 Hearing Date: **2-16-2022**

Project: 1400 8th St. Agenda Item No: **13**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☒ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Private Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- No objection
- Note: An approved grading and drainage plan will be required at building permit if any of the following conditions are met: 500cy of grading, 1000 sf of new building or 10000 sf of paving.

RESOLUTION/COMMENTS:

Water:

Code:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____