DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2021-006337 Hearing Date: **1-5-2022**

Project: NMDOT D-3 Agenda Item No: **24**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Please provide a diagram showing existing drainage does not cross over proposed property lines or provide a cross lot drainage easement naming beneficiaries and maintenance responsibilities.
- Note: An approved Grading and Drainage plan will be required for future development if any of the following conditions are met: 500 cy of grading, 1,000 sf of proposed structure, or 10,000 sf of propose paving.

RESOLUTION/COMMENTS:

Water:

Code:

Parks & Rec.:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____