DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006350 AGENDA ITEM NO: 25
Menaul and Chelwood Park

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Show existing sidewalk widths along both Menaul Blvd. (a community principal arterial) and Chelwood Park (major collector street). Ensure that these will meet minimum sidewalk width requirements.

If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: January 5, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)