DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006381 AGENDA ITEM NO: 19
William Street

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Show right-of-way for William Street, pavement section width, and sidewalk width. A minimum 5-foot sidewalk is required along William Street. Any deviation from the required sidewalk width shall require a DRB Determination by providing a justification letter.

If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: January 12, 2022

---

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)