DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

David G. Gutierrez, PE, Senior Engineer | 505-924-3695 dggutierrez@cabq.gov

DRB Project Number: 2021-006381 Hearing Date: **01-12-2022**

Project: **LOTS 9 & 10, BLOCK 1, HOSHOR ADDITION** zoned **R-1B** Agenda Item No: **19**

| | | | |
|---|---|---|---|
| ☒ Sketch Plat | ☐ Minor Preliminary / Final Plat | ☐ Preliminary Plat | ☐ Final Plat |
| ☐ Temp Sidewalk Deferral | ☐ Sidewalk Waiver/Variance | ☐ Site Plan for Bldg. Permit<br>☐ Site Plan for Subdivision | ☐ Bulk Land Plat |
| ☐ SIA Extension | ☐ DPM Variance | ☐ Vacation of Public Easement | ☐ Vacation of Public Right of Way |

**ENGINEERING COMMENTS:**

- Hydrology has no objection to the proposed lot adjustment. However, the site will require a cross lot drainage easement to be completed prior to final plat approval.
- For future plans an approved grading and drainage plan is required prior to Building Permit if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving).

**RESOLUTION/COMMENTS:**

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____