DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2022-006497 Hearing Date: **06-08-2022**

Project: Lot 2 Block 4B, Sunport Park Agenda Item No: **2 & 3**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☒ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☒ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has sent comment letter (M15D050) on 02/18/22. The project will have to accommodate the drainage from the vacation into their development's drainage outfall once this is vacated.

Vacation of Public Right of Way –

- Hydrology has no comment on the vacation.

Site Plan for Building Permit –

- Hydrology needs an approved Grading & Drainage Plan prior to Site Plan for Building Permit approval.

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____