Albuquerque Bernalillo County
Water Utility Authority

Development Review Board (DRB)
Review Comments
Utility Development Section
Reviewer: Blaine Carter, P.E.
Phone: 505.415.9188

DRB Project No:	Date:	Item No:
PR-2022-006568	02/09/2022	#13
Zone Atlas Page: C-20	Legal Description: Lot(s) 4 & 5 UNIT 3 TRACT 3, NORTH ALBUQUERQUE ACRES Location: WILSHIRE AVE NE between HOLBROOK and VENTURA	
Request For: PS-2022-00011 – SKETCH PLAT		

ABCWUA Comment:

Please provide written description of how the following comments were addressed with the next submittal.

1. Request an availability/serviceability statement online at the following link: http://www.abcwua.org/Availability_Statements.aspx. Requests shall include fire marshal requirements. An executed statement must be obtained prior to approval.
2. This project is within the adopted service area.
3. Pro rata is not owed for this property.
4. Utility Plan:
    a. Provide a utility plan that indicates the location of proposed services.
    b. Coordinate with NM 811 to field locate and survey the existing public water and sewer infrastructure. If existing infrastructure is not within the existing easements, dedicate additional easement to provide the minimum widths over the actual pipe locations.
5. Infrastructure List:

a. Improvements are anticipated to be required for this project. Upon issuance of the Availability Statement, include the public infrastructure items in the infrastructure list.

6. Easements:
    a. Exclusive public water and sanitary sewer easements are required for all public lines that are to be constructed outside of any dedicated rights-of-way. A minimum width easement of 20' is required for a single utility and 25' for water and sewer both within the same easement. Easements for standard sized water meters need to be 5'x5' and include the length of the water service if located on private property. For larger meters that require a meter vault, a 35'x35' easement is required. Actual easement widths may vary depending on the depth of the lines to be installed.
    b. Side yard easements are not acceptable for public waterline or sanitary sewer. If no other corridor is available for such extensions, a separate tract that is owned and maintained by the Homeowners Association (HOA) shall be created and an exclusive public water and/or sanitary sewer easement shall be granted to the Water Authority along this tract.