DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2022-006614 Hearing Date: **3-2-2022**

Project: 6508 Jade Dr Agenda Item No: **22**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- There is currently a separate 25' Drainage Easement behind this lot which carries a 60" RCP. The easement through this property is no longer needed.
- No objection to the vacation.
- Note: Please conform to the approved Grading and Drainage plan (E10D113) for this site which has retention ponding in several locations including the back of this property.

RESOLUTION/COMMENTS:

Water:

Code:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____