Albuquerque Bernalillo County
Water Utility Authority

# Development Review Board (DRB)
# Review Comments
# Utility Development Section
# Reviewer: Blaine Carter, P.E.
# Phone: 505.415.9188

| DRB Project No: | Date: | Item No: |
|---|---|---|
| PR-2022-006630 | 03/02/2022 | #13 |
| **Zone Atlas Page:** G-11 | **Legal Description: Lot(s) 17, OXBOW VILLAGE** **Location: 3809 OXBOW VILLAGE LN NW** | |
| **Request For:** SD-2022-00024 – VACATON OF PUBLIC EASEMENT SD-2022-00025 – PRELIMINARY/FINAL PLAT | | |
| | | |

**ABCWUA Comment:**

**Please provide written description of how the following comments were addressed with the next submittal.**

1. Please dimension the final ABCWUA easement. Does 25 feet of width remain?
2. Please show the distances from the water and sewer mains to the easement lines.
3. Please clarify the portions that have been modified by other plats, are these shown as modified or per the original easement?