DEVELOPMENT HEARING OFFICER

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-006657 AGENDA ITEM NO: 3
1000 San Mateo

SUBJECT: Preliminary/Final Plat

ENGINEERING COMMENTS:

1. Proposed sidewalk widths appear to meet current standards. Please ensure a minimum 4-foot wide ADA pathway is provided around any obstacles such as trees.

2. No objection.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: November 8, 2023

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __