DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-006769 AGENDA ITEM NO: 11
1820 Gabaldon

SUBJECT: Preliminary/Final Plat, Sidewalk Waiver, Vacation of Private Easement

ENGINEERING COMMENTS:

1. Applicant has provided adequate justification for DRB determinations on roadway and sidewalk width to remain. Access easement beyond end of cul-de-sac provides adequate alternative to hammerhead for turnaround.
2. No objection

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: September 21, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)