Albuquerque Bernalillo County
Water Utility Authority

Development Review Board (DRB)
Review Comments
Utility Development Section
Reviewer: Blaine Carter, P.E.
Phone: 505.415.9188

DRB Project No:	Date:	Item No:
PR-2022-006846	6/29/2022	#10
Zone Atlas Page: C-12	Legal Description: Lot(s) A-1-B-1, FOUNTAIN HILLS PLAZA SUBDIVISION Location: NUNZIO AVE NW AND PARDISE BLVD NW	
Request For: SD-2022-00101 – PRELIMINARY/FINAL PLAT		

ABCWUA Comment:

Please provide written description of how the following comments were addressed with the next submittal.

1. Availability Statement #200301 was issued on July 14, 2020 and is the basis for Service Connection Agreement C-21-8. This is a further subdivision of the previously created lot.
2. Routine connections remain available, no additional infrastructure is warranted for this lot split.
3. Include the following note:
    i. "Existing public water and/or sanitary sewer infrastructure may not be constructed or sized to adequately serve potential future development. Improvement or upsizing of existing public infrastructure may be required as a condition of future development approval."
4. Pro rata is not owed for this property.
5. Easements (Standard Comments):
    a. Include all public water and/or sanitary sewer easements on the plat, including those that are adjacent to the subject property's boundaries. Surveyor shall field verify the location of existing public water and/or sanitary sewer infrastructure to determine if existing public water and/or sanitary sewer easements are sufficient. If the easement(s) does not exist, a new easement shall be

granted. The width of the easement shall be the standard width, unless specified by the Water Authority.

b. Exclusive public water and sanitary sewer easements are required for all public lines that are to be constructed outside of any dedicated rights-of-way. A minimum width easement of 20' is required for a single utility and 25' for water and sewer both within the same easement. Easements for standard sized water meters need to be 5'x5' and include the length of the water service if located on private property. For larger meters that require a meter vault, a 35'x35' easement is required. Actual easement widths may vary depending on the depth of the lines to be installed.

c. If existing conditions consist of a shared easement with public waterline and/or sanitary sewer along with other utilities, this existing easement may remain as is without the need for an exclusive easement, as approved by the Water Authority.