DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 003419 AGENDA ITEM NO: 9
Campbell Road

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. A five-foot sidewalk is required on Campbell Road, or a sidewalk waiver shall be requested.
2. Show right-of-way width and roadway width for Campbell Road. Meet the required minimum width per DPM standards for local roads.
3. A firm surface shall be in place for the new easement prior to plat approval. Alternatively, an infrastructure list shall be generated.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: April 13, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)