DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006859 AGENDA ITEM NO: 14
3428 Kathryn Avenue

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Meet minimum requirements for right-of-way width, roadway width, and sidewalk width (5 feet) for Kathryn Avenue which is classified as a local street. Label these elements on an exhibit. Also provide a dimension from the back of sidewalk to the back of curb.

2. Fence shall be outside of right-of-way.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: April 20, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)