DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-006861 AGENDA ITEM NO: 10
47th Street and Bluewater

SUBJECT: Preliminary/Final Plat

ENGINEERING COMMENTS:

1. A minimum 5-foot wide sidewalk is required on Bluewater from east to the west property line. Please provide a diagram dimensioning this along with the property line.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: September 21, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)