DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

David G. Gutierrez, PE, Senior Engineer | 505-924-3695 dggutierrez@cabq.gov

DRB Project Number: 2022-006872 Hearing Date: **04-27-2022**

Project: **LOTS 1 THRU 16 & LOTS 41 THRU 56, VALLEY VIEW ADDITION** zoned **MX-M** Agenda Item No: **16**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has no objection to the proposed lot consolidation.
- Please correct the following on the plat: Lots 8 (duplicate) through 15 should follow as lot 9 through 16.
- Any future plans an approved grading and drainage plan is required prior to Building Permit if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving).

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____