DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006885 AGENDA ITEM NO: 13
Yale and Silver

SUBJECT: Plat

ENGINEERING COMMENTS:

1. Yale Boulevard is a minor arterial for which right-of-way appears to be needed. Bike lanes are required on Yale Boulevard per the approved Master Plan. Provide a cross-section for Yale Boulevard to incorporate this requirement for right-of-way determination purposes.

2. Sidewalk on Silver Avenue should be a minimum of 5 feet wide, and sidewalk on Yale Boulevard should be a minimum of 6 feet wide. Label these on the exhibit provided.

3. Silver Avenue is a local street that incorporates a bicycle boulevard.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: April 27, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)