DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE, Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2022-006908 Hearing Date: **5-4-2022**

Project: 1515 Yale Agenda Item No: **11**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- No objection
- **For future development** an approved Grading and Drainage plan will be required prior to building permit if any of the following conditions are met: 500 cy of grading, 1,000 sf of proposed structure, or 10,000 sf f proposed paving

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____