DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006935 AGENDA ITEM NO: 15
10915 Juan Tabo - Juan Tabo Place and Comanche

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

PLATTING ACTION:

1. Provide 5-foot sidewalk along frontage. Place onto an infrastructure list. Show cross-section to ensure it will be located within right-of-way, and dedicate any right-of-way as necessary.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: May 11, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)