DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-006935 AGENDA ITEM NO: 9
10900, 10901, 10915 Juan Tabo

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

PLATTING ACTION:

1. Provide 5-foot sidewalk along frontage of existing Juan Tabo. Place onto an infrastructure list. Show cross-section to ensure it will be located within right-of-way, and dedicate any right-of-way as necessary.

2. For the new roadway infrastructure, follow DPM requirements with regard to right-of-way width, roadway width, and sidewalk. All infrastructure shall be placed onto an infrastructure list and be reviewed through the work order process.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: July 13, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)