


UPTOWN CONNECT  
UPTOWN BLVD.  
ALBUQUERQUE, NM 87123

## DESIGN DEVELOPMENT

REVISIONS




DRAWN BY	JTS/BJB/DEC
REVIEWED BY	FCA/IMA
DATE	06/04/2024
PROJECT NO.	IA 2625 XX-XXXX

DRAWING NAME

# FIRE HYDRANT LOCATION & ACCESS PLAN

SHEET NO.


## FIRE 1



**Isaacson & Arfman, Inc.**  
Civil Engineering Consultants

128 Monroe Street NE  
Albuquerque, NM 87108  
505-268-8828 | [www.iacliv.com](http://www.iacliv.com)

© 2020 Isaacson & Arfman, Inc.  
This design, calculations, and  
concepts are owned by and  
remain the property of Isaacson &  
Arfman, Inc. and no part thereof  
shall be utilized by any other  
firm or corporation for any  
purpose whatsoever except with  
the written permission of  
Isaacson & Arfman, Inc.



PLAZA TOWER:

MAX. BUILDING HEIGHT = 68'-0"

LEVEL 1 = 38,915 SF  
OCCUPANCY TYPE = M  
CONSTRUCTION TYPE = 1-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 2,250 GPM / 2 = 1,125 GPM -  
MIN. 1,750 GPM  
REQUIRED 1 FIRE HYDRANT  
PROVIDED: 1 FIRE HYDRANT

LEVEL 2 = 8,387 SF  
OCCUPANCY TYPE = A and R-2  
CONSTRUCTION TYPE = V-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 1,500 GPM /2 = 750 GPM -  
MIN. 1,750 GPM  
REQUIRED 1 FIRE HYDRANT  
PROVIDED: 1 FIRE HYDRANT

LEVELS 3-5 = 13,113 SF  
OCCUPANCY TYPE = R-2  
CONSTRUCTION TYPE = V-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 2,250 GPM /2 = 1,125 GPM -  
MIN. 1,750 GPM  
REQUIRED 1 FIRE HYDRANT  
PROVIDED: 1 FIRE HYDRANT

NORTH TOWER:

MAX. BUILDING HEIGHT = 85'-0"

LEVEL 1 = 46,833 SF  
OCCUPANCY TYPE = B  
CONSTRUCTION TYPE = 1-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 2,250 GPM / 2 = 1,125 GPM -  
MIN. 1,750 GPM  
REQUIRED 1 FIRE HYDRANT  
PROVIDED: 1 FIRE HYDRANT

LEVEL 2 = 32,231 SF  
OCCUPANCY TYPE = B  
CONSTRUCTION TYPE = 1-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 2,000 GPM / 2 = 1,000 GPM -  
MIN. 1,750 GPM  
REQUIRED 1 FIRE HYDRANT  
PROVIDED: 1 FIRE HYDRANT

LEVELS 3-7 = 144,715 SF  
OCCUPANCY TYPE = R-2  
CONSTRUCTION TYPE = III-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 6,750 GPM / 2 = 3,375 GPM -  
REQUIRED 4 FIRE HYDRANT  
PROVIDED: 4 FIRE HYDRANT

BASEMENT GARAGE PARKING:

82,640 SF  
OCCUPANCY TYPE = S-2  
CONSTRUCTION TYPE = 1-A  
SPRINKLER SYSTEM IN BLDG.  
FIRE FLOW = 3,000 GPM / 2 = 1,500 GPM -  
MIN. 1,750 GPM  
REQUIRED 1 FIRE HYDRANT  
PROVIDED: 1 FIRE HYDRANT