DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2021-006960 Hearing Date: **08-31-2022**

Project: 6501 Indian School Rd NE (Nusenda) Agenda Item No: **1**

| | | | |
|---|---|---|---|
| ☐ Sketch Plat | ☐ Minor Preliminary / Final Plat | ☐ Preliminary Plat | ☐ Final Plat |
| ☐ Temp Sidewalk Deferral | ☐ Sidewalk Waiver/Variance | ☒ Site Plan for Bldg. Permit<br>☐ Site Plan for Subdivision | ☐ Bulk Land Plat |
| ☐ SIA Extension | ☐ DPM Variance | ☐ Vacation of Public Easement | ☐ Vacation of Public Right of Way |

**ENGINEERING COMMENTS:**

- Hydrology has no objection to the Site Plan Amendment.

**RESOLUTION/COMMENTS:**

Code Enforcement:

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____