DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-006968 AGENDA ITEM NO: 8
Sage and 86th

SUBJECT: Sketch Site

ENGINEERING COMMENTS:

1. Please provide a cross sections at both 86th and Sage dimensioning ROW, curb & gutter and Walls or fences.
2. 6' sidewalk is required. Repair or replace any broken sections.
3. A TCL will be required for this site prior to approval.
4. Please prepare a Traffic Scoping form to determine if a Traffic Impact Study will be required.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: August 3, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)