DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 006977 AGENDA ITEM NO: 14
5616 Cielo del Oeste

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Cielo del Oeste and 57th Street shall have 5-foot wide sidewalk per new DPM requirements. In order to maintain the sidewalks at current width, provide a justification letter for a DRB Determination as part of the next application.
2. Each lot shall have its own separate access.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or rmichel@cabq.gov

DATE: May 18, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)