DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 007000 AGENDA ITEM NO: 13
312 Alamo Street

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Alamo Street is required to have 5-foot wide sidewalk per the new DPM requirements.
2. Fencing shall be relocated outside of right-of-way.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or rmichel@cabq.gov

DATE: May 18, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)