DEVELOPMENT HEARING OFFICER - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2022-007153 Hearing Date: **10-11-2023**

Project: Tracts A-s, A-2, & A-3, Lands of Sawmill Bellamah Properties Agenda Item No: **2**

☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Bulk Land Plat
☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has an approved Conceptual Grading & Drainage Plan (J13D076A) with engineer's stamp 10/18/2022 for **Tract A-1**.
- Hydrology has an approved Conceptual Grading & Drainage Plan (J13D076B) with engineer's stamp 02/28/2023 for **Tract A-2**.
- Hydrology has no objection to the platting action.

- Comment – **Tract A-1 & A-2** - Prior to submitting for Building Permit, a licensed New Mexico civil engineer will need to submit a Grading & Drainage Plan to Hydrology for review & approval if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving).

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____