DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-007000 AGENDA ITEM NO: 11
4517 5th Street

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. 5th Street is required to have 5-foot wide sidewalk per the new DPM requirements. Please provide a cross section that shows and dimensions curb and gutter, ROW, and sidewalk width.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: July 13, 2022

---

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)