Albuquerque Bernalillo County
Water Utility Authority

# Development Review Board (DRB)
# Review Comments
# Utility Development Section
# Reviewer: Blaine Carter, P.E.
# Phone: 505.415.9188

| DRB Project No: | Date: | Item No: |
|---|---|---|
| PR-2022-007324 | 07/20/2022 | #5 |
| Zone Atlas Page: J-13 | Legal Description: Lot(s) BLOCK 4, TRACTION PARK & CITY ELECTRIC<br>Location: 2100 & 2124 CENTRAL SW between RIO GRANDE BLVD and CLAYTON ST | |
| Request For: PS-2022-00140 – SKETCH PLAT | | |
| | | |

**ABCWUA Comment:**

**Please provide written description of how the following comments were addressed with the next submittal.**

1. An Availability Statement will NOT be required with this plat as shown.
2. This project is within the adopted service area.
3. Pro rata is not owed for this property.
4. Plat:
    a. When existing infrastructure is located along the property frontage(s), but plans are uncertain and no Availability Statement is being required, the following language shall be included on the plat for approval:
        i. "Existing public water and/or sanitary sewer infrastructure may not be constructed or sized to adequately serve potential future development. Improvement or upsizing of existing public infrastructure may be required as a condition of future development approval."
5. Easements:

a. Include all public water and/or sanitary sewer easements on the plat, including those that are adjacent to the subject property's boundaries. Surveyor shall field verify the location of existing public water and/or sanitary sewer infrastructure to determine if existing public water and/or sanitary sewer easements are sufficient. If the easement(s) does not exist, a new easement shall be granted. The width of the easement shall be the standard width, unless specified by the Water Authority.
b. Exclusive public water and sanitary sewer easements are required for all public lines that are to be constructed outside of any dedicated rights-of-way. A minimum width easement of 20' is required for a single utility and 25' for water and sewer both within the same easement. Easements for standard sized water meters need to be 5'x5' and include the length of the water service if located on private property. For larger meters that require a meter vault, a 35'x35' easement is required. Actual easement widths may vary depending on the depth of the lines to be installed.
c. The surveyor shall field verify the location of existing private water and/or private sanitary sewer services to determine if private service easements are needed to preserve the existing service(s) for the newly created lots. The width of the private service easement shall be determined by the engineer or surveyor.