DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-007509 AGENDA ITEM NO: 9
926 Avenida Estrellita NE

SUBJECT: Sketch

ENGINEERING COMMENTS:

1. Please provide a cross section or plan showing the property line, sidewalk and edge of roadway. A minimum 5-foot sidewalk is requested for this area. You may also request a DRB Determination to allow a sidewalk that does not meet this width with a justification letter as part of your full DRB submittal.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: August 31, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)