DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2022-007518 Hearing Date: **08-31-2022**

Project: Tract B-1, Cibola Loop Subdivision Agenda Item No: **12**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- The existing Cibola Loop Detention Pond and the Pond's outfall are currently on Tract B-1 and the 40' Private Access Easement.



- Hydrology needs to approve a Drainage Report and revised Grading Plan for the Cibola Loop Detention Pond prior to approving any platting action.
- Hydrology will need to approved Tract B-1 Grading & Drainage Plan is required prior to Building Permit if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving).

RESOLUTION/COMMENTS:

Code Enforcement:

☐ APPROVED DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG

☐ DENIED Delegated For: _____

SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT

DEFERRED TO _____

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____