DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-007520 AGENDA ITEM NO: 8
8235 Washington St. NE

SUBJECT: Sketch

ENGINEERING COMMENTS:

1. Please provide a minimum 5-foot wide sidewalk along Washington the length of this property.
2. Provide a cross section or plan showing the property line, new sidewalk and edge of roadway to ensure the new sidewalk will fit within existing ROW. ROW dedication may be required.
3. A TCL (Traffic Circulation Layout) will be required prior to approval.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: August 31, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)