DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2022-007523 AGENDA ITEM NO: 11
301 59th St.

SUBJECT: Sketch

ENGINEERING COMMENTS:

1. Please provide a cross section or plan that dimensions ROW and sidewalk width. 5' sidewalk is required along both Avalon and 59th. A 4' clear path is required around obstructions in the sidewalk.

*Please remember to send an electronic copy of all supplemental submittal documents.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: September 14, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)