DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

David G. Gutierrez, PE, Senior Engineer | 505-924-3695 dggutierrez@cabq.gov

DRB Project Number: 2022-007569 Hearing Date: **09-14-2022**

Project: **LOT 1, UNIT 6, VOLCANO CLIFFS SUBDIVISION** zoned **R-A** Agenda Item No: **13**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology will need an approved grading and drainage plan completed by a New Mexico registered professional Civil Engineer for the proposed site plan.
- The site will require infrastructure improvements that may include, but is not limited to, sidewalk, curb and gutter, and storm sewer improvements for the site. Necessary drainage infrastructure will be determined during the grading and drainage plan review and approval process. The necessary infrastructure will need to be financially guaranteed or constructed prior to approval of the proposed plat.

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____

David G. Gutierrez, PE, Senior Engineer | 505-924-3695 dggutierrez@cabq.gov

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____