DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2022-007623 Hearing Date: **09-21-2022**

Project: Lot 7-B-1 Meridian Business Park Agenda Item No: **13**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☒ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has received a Grading & Drainage Plan (K10D023K) on Sept 12, 2022. Please note that Hydrology has a current que time of 5 weeks.
- Existing Public Detention Pond Easement needs to be vacated if the proposed rework of the proposed detention pond's shape is outside the existing easement.
- Please vacate the existing Agreement & Covenant for the detention pond.
- Please add the City's standard drainage easement language for the new proposed detention pond. See attachment.

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRAINAGE EASEMENT LANGUAGE FOR SUBDIVISION PLAT

Areas designated on the accompanying plat as "drainage easements" are hereby dedicated by the owner as a perpetual easement for the common use and benefit of the various lots within the subdivisions for the purpose of permitting the conveyance of storm water runoff and the constructing and maintaining of drainage facilities in accordance with standards prescribed by the City of Albuquerque. Grantor shall construct drainage facilities in the easement in accordance with standards prescribed by the City and plans and specifications approved by the City Engineer in accordance with the Drainage Report with engineer's stamp date _____and the Grading and Drainage Plan with engineer's stamp date _____ which report and plans are on file in the office of the City Engineer File #_____. No fence, wall, planting, building or other obstruction may be placed or maintained in easement area without approval of the City Engineer of the City of Albuquerque. There also shall be no alteration of the grades or contours in said easement area without the approval of the City Engineer. It shall be the duty of the lot owners of this subdivision to maintain said drainage easement and facilities at their cost in accordance with standards prescribed by the City of Albuquerque. The City shall have the right to enter periodically to inspect the facilities. In the event said lot owners fail to adequately and properly maintain drainage easement and facilities, at any time following fifteen (15) days written notice to said lot owners, the City may enter upon said area, perform said maintenance, and the cost of performing said maintenance shall be paid by applicable lot owners proportionately on the basis of lot ownership. In the event lot owners fail to pay the cost of maintenance within thirty (30) days after demand for payment made by the City, the City may file a lien against all lots in the subdivision for which proportionate payment has not been made. The obligations imposed herein shall be binding upon the owner, his heirs, and assigns and shall run with all lots within this subdivision.

The Grantor agrees to defend, indemnify, and hold harmless, the City, its officials, agents and employees from and against any and all claims, actions, suits, or proceedings of any kind brought against said parties for or on account of any matter arising from the drainage facility provided for herein or the Grantor's failure to construct, maintain, or modify said drainage facility.

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____