DEVELOPMENT HEARING OFFICER

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2023-008238 AGENDA ITEM NO: 1
Eagle Rock

SUBJECT: Preliminary/Final Plat

ENGINEERING COMMENTS:

1. Eagle Rock is a local road and requires 5' sidewalk with a 5'-6' landscape buffer and curb and gutter. This along with the remaining full width of the roadway needs to be placed on an infrastructure list and done through work order.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: February 22, 2023

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)