

DEVELOPMENT FACILITATION TEAM

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2023-008325  
2026 Central SW

AGENDA ITEM NO:

SUBJECT: Sketch

ENGINEERING COMMENTS:

1. Please provide diagram showing existing sidewalk widths. Central is a Principal Arterial within a Premium Transit Corridor and requires 8-10' sidewalk and a 6-8' Landscape buffer.
2. An approved TCL will be required prior to site plan.
3. Please fill out and submit a Traffic Scoping Form to Matt Grush [mgrush@cabq.gov](mailto:mgrush@cabq.gov) to determine if a TIS is required.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.  
Transportation Development  
505-924-3991 or [earmijo@cabq.gov](mailto:earmijo@cabq.gov)

DATE: March 15, 2023

---

ACTION:

APPROVED \_\_; DENIED \_\_; DEFERRED \_\_; COMMENTS PROVIDED \_\_; WITHDRAWN \_\_

DELEGATED: \_\_\_\_\_ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)