

AGENDA ITEM: DFT Project Number: PR-2023-008423

Application Number: SI-2023-00606 Project Name: 4821 Pan American West – Lexus

PARKS AND RECREATION DEPARTMENT COMMENTS & APPLICANT RESPONSES

Comments from: Parks and Rec

HEARING DATE: 4/5/23

COMMENT RESPONSES IN BLUE BY AYER DESIGN GROUP, BIRKIE AYER, JR., P.E. APRIL 13, 2023

1. Street Trees are required every 25' on center. Please clarify whether existing trees meet this requirement on the landscape plan.

RESPONSE: We've revised the landscape plan with dimensions and slightly adjusted the layout of proposed trees to ensure we meet the 25' required spacing.