DEVELOPMENT HEARING OFFICER

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2023-008856 AGENDA ITEM NO: 2
807 Bellamah NW

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Bellamah is a major collector and requires 6' sidewalk with 5-6' landscape buffer. The infrastructure list only shows a proposed 5' sidewalk here. Please update the infrastructure list to show 6' sidewalk.

2. The justification for ROW to remain as in on Bellamah is acceptable. Transportation has no objection.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: November 8, 2023

---

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)